

Implementing 2021 MMC Chapters 1-6

CP-24-00060

1A/R 2 T MI

1. If an owner refuses entry to a building or premises, code officials have recourse to every remedy provided by law to secure entry.
 A. TRUE B. FALSE **Ref: Section 104.4 Right of entry.**
2. A permit is not required for portable heating or gas appliances.
 A. TRUE B. FALSE **Ref: Section 106.2** Permits are required for portable heating or gas appliances with inputs greater than 30,000 BTU/hr.
3. Code officials may require additional construction documents at any point during construction.
 A. TRUE B. FALSE **Ref: Section 107.1 Construction documents.**
4. Occupiable spaces include spaces intended primarily for use as storage rooms or equipment rooms.
 A. TRUE B. FALSE **Ref: Chapter 2 Definitions. Occupiable Space.**
5. Condensate drains may be connected to a plumbing drain or vent pipe.
 A. TRUE B. FALSE **Ref: Section 307.2.1.1 Condensate discharge.**
6. Separation is not required between intake air openings and living space exhaust air openings of an individual dwelling unit or sleeping unit where an approved factory-built intake/exhaust combination termination fitting is used to separate the air streams in accordance with the manufacturer's instructions.
 A. TRUE B. FALSE **Ref: Section 401.4 Intake opening location.**
7. Whole-house ventilation-type attic fans are not permitted to discharge into the attic space of dwelling units with private attics.
 A. TRUE B. FALSE **Ref: Section 501.3 Exhaust discharge. Exception 1.**
8. Exhaust ventilation is not required for spaces used to store of distilled spirits in barrels conforming to the requirements of the International Fire Code.
 A. TRUE B. FALSE **Ref: Section 5.2.9.5 Flammable and combustible liquids. Exception 2.**
9. Clothes dryer exhaust ducts may be connected to a vent connector.
 A. TRUE B. FALSE **Ref: Section 504.4 Exhaust installation.**
10. Static ceiling radiation dampers may be installed in any system designed to operate during a fire.
 A. TRUE B. FALSE **Ref: Section 607.6.2.1.2 Static systems. Exceptions 1 and 2.**